



İSTANBUL ÜNİVERSİTESİ
Mühendislik Fakültesi
Kimya Mühendisliği Bölümü




Sayı: 7493216-939-02-210462

20.09.2017

Analysis Performed	Limit	Tardigrade ECTX 220	
		Concentration after 24 hours	Concentration after 7 days
Aluminum (Al), $\mu\text{g/L}$	≤ 200	133	133
Antimon (Sb), $\mu\text{g/L}$	≤ 5	<5	<5
Arsenic (As), $\mu\text{g/L}$	≤ 10	<10	<10
Barium (Ba), $\mu\text{g/L}$	≤ 1000	<10	<10
Cadmium (Cd) miktarı, $\mu\text{g/L}$	≤ 5	<5	<5
Krom (Cr), $\mu\text{g/L}$	≤ 50	12	12
Iron (Fe), $\mu\text{g/L}$	≤ 200	82	82
Lead (Pb), $\mu\text{g/L}$	≤ 25	9	9
Manganese (Mn), $\mu\text{g/L}$	≤ 50	26	26
Mercury (Hg), $\mu\text{g/L}$	≤ 1	<1	<1
Nickel (Ni), $\mu\text{g/L}$	≤ 20	<10	<10
Selenium (Se), $\mu\text{g/L}$	≤ 10	<10	<10

The sample of Tardigrade ECTX 220 has been found to give a non-cytotoxic response and therefore it has been found to comply with the requirements of BS 6920: Part 1: Clause 8, according to the elements given in Table 1.



Ismail Aydın
Prof. Dr. İsmail AYDIN
Istanbul University
Engineering Faculty
Chemical Engineering Department