



İSTANBUL ÜNİVERSİTESİ  
Mühendislik Fakültesi  
Kimya Mühendisliği Bölümü



Sayı: 7493216-939-02-210462

05.06.2018

Analysis Performed	Limit	Tardigrade ECWT 250	
		Concentration after 24 hours	Concentration after 7 days
Aluminum (Al), µg/L	≤200	<1	<1
Antimon (Sb), µg/L	≤5	<1	<1
Arsenic (As), µg/L	≤10	<1	<1
Barium (Ba), µg/L	≤1000	<10	<10
Cadmium (Cd) miktarı, µg/L	≤5	-	-
Krom (Cr), µg/L	≤50	<1	<1
Iron (Fe), µg/L	≤200	<10	<10
Lead (Pb), µg/L	≤25	-	-
Manganese (Mn), µg/L	≤50	<1	<1
Mercury (Hg), µg/L	≤1	<1	<1
Nickel (Ni), µg/L	≤20	<1	<1
Selenium (Se), µg/L	≤10	<1	<1

The sample of Tardigrade ECWT 250 has been found to give a non-cytotoxic response and therefore it has been found to comply with the requirements of BS 6920: Part 1: Clause 8, according to the elements given in Table 1.

Prof. Dr. Ismail AYDIN  
Istanbul University - Cerrahpasa  
Engineering Faculty  
Chemical Engineering Faculty

